



Pacific Northwest
NATIONAL LABORATORY

*Proudly Operated by **Battelle** Since 1965*

VOLTTRON™ ENERGYPLUS™ AGENT

For Co-Simulation and Control Validation

CHAD CORBIN, PH.D.

Pacific Northwest National Laboratory

VOLTTRON™ 2016

Co-Simulation for Building Controls Development and Validation



Pacific Northwest
NATIONAL LABORATORY

Proudly Operated by **Battelle** Since 1965

VOLTTRON™ EnergyPlus™ Agent

- ▶ Federates message exchange between VOLTTRON™ applications and EnergyPlus™
- ▶ Enables “hardware in the loop” testing of algorithms before deploying to buildings
 - Rapid prototype of algorithms
 - Validate
 - Build confidence
 - Test range of operating conditions




EnergyPlus™

- ▶ Whole building energy simulation program
- ▶ Residential to large commercial
- ▶ Energy systems can be controlled through BCVTB interface



VOLTRON™ ↔ EnergyPlus™ Communication Flow



Multiple Input Interfaces for Application Flexibility



Pacific Northwest
NATIONAL LABORATORY

Proudly Operated by **Battelle** Since 1965

▶ PubSub Interface

- Useful for quick and dirty development and testing
- When you need additional abstraction between “building” and application
- **NOT** the same as the old Actuator pubsub method

▶ Actuator (RPC) Interface

- Looks and behaves like an actuator
- No schedule checking

```
def subscribe(self):
    for key, obj in self.input().iteritems():
        if obj.has_key('topic'):
            callback = self.onMatchTopic
            topic = obj.get('topic')
            keyCaps = 'onMatch'+key[0].upper()+key[1:]
            if obj.has_key('callback'):
                callbackstr = obj.get('callback')
                if (hasattr(self, callbackstr) and
                    callable(getattr(self, callbackstr, None))):
                    callback = getattr(self, callbackstr)
            elif (hasattr(self, keyCaps) and
                  callable(getattr(self, keyCaps, None))):
                callback = getattr(self, keyCaps)
            log.info('subscribed to ' + topic)
            self.vip.pubsub.subscribe(peer='pubsub', prefix=topic, callback=callback)
```

```
@RPC.export
def request_new_schedule(self, requester_id, task_id, priority, requests):[]

@RPC.export
def request_cancel_schedule(self, requester_id, task_id):[]

@RPC.export
def get_point(self, topic, **kwargs):[]

@RPC.export
def set_point(self, requester_id, topic, value, **kwargs):[]

@RPC.export
def revert_point(self, requester_id, topic, **kwargs):[]

@RPC.export
def revert_device(self, requester_id, device_name, **kwargs): []
```

Mimics Building Automation System Output

► PubSub Interface

- Configurable output format
- Point by point, grouped into topics

```
...
"outputs" : {
  "myVar1" : {
    ...
    "topic" : "pnnl/building/device/weatherstation",
    "field" : "outdoorDryBulbTemperature",
    "meta" : {"units": "C", "tz": "UTC", "type": "float"}
  },
  "myVar2" : {
    ...
    "topic" : "pnnl/building/device/weatherstation",
    "field" : "surfaceIncidentRadiation",
    "meta" : {"units": "W", "tz": "UTC", "type": "float"}
  },
  "myVar3" : {
    ...
    "topic" : "pnnl/building/device/vav/zonetemperature",
    "meta" : {"units": "C", "tz": "UTC", "type": "float"}
  },
  ...
},
...
```

```
[
  {
    'outdoorDryBulbTemperature': 32.0,
    'surfaceIncidentRadiation': 789,
  },
  {
    'outdoorDryBulbTemperature': {"units": "C", "tz": "UTC", "type": "float"},
    'surfaceIncidentRadiation': {"units": "W", "tz": "UTC", "type": "float"}
  }
]
[22.0, {"units": "C", "tz": "UTC", "type": "float"}]
```


Communication with EnergyPlus™ uses BCVTB Interface



Pacific Northwest
NATIONAL LABORATORY

Proudly Operated by **Battelle** Since 1965

```
{
  "properties" : {
    "identity" : "platform.actuator",
    "model" : "eplus/1ZoneUncontrolled.idf",
    "weather" : "eplus/USA_CO_Golden-NREL.724666_TMY3.epw",
    "bcvtb_home" : "bcvtb"
  },
  "inputs" : {
    "shadeSchedule" : {
      "name" : "WindowShadeSch",
      "type" : "schedule",
      "topic" : "building/windowshades",
      "field" : "schedule"
    },
    "extLightSchedule" : {
      "name" : "ExtLightSch",
      "type" : "schedule",
      "topic" : "building/exteriorlights",
      "field" : "schedule"
    }
  },
  "outputs" : {
    "outdoorDryBulb" : {
      "name" : "ENVIRONMENT",
      "type" : "Site Outdoor Air Drybulb Temperature",
      "topic" : "building/weatherstation",
      "field" : "outdoorDryBulbTemperature",
      "meta" : {"units": "C", "tz": "UTC", "type": "float"}
    },
    "incidentRadiation" : {
      "name" : "Zn001:Wall001:Win001",
      "type" : "Surface Outside Face Incident Solar Radiation Rate per Area",
      "topic" : "building/weatherstation",
      "field" : "surfaceIncidentRadiation",
      "meta" : {"units": "", "tz": "UTC", "type": "float"}
    },
    "horizontalRadiation" : {
      "name" : "ENVIRONMENT",
      "type" : "Site Diffuse Solar Radiation Rate per Area",
      "topic" : "building/weatherstation",
      "field" : "totalHorizontalRadiation",
      "meta" : {"units": "C", "tz": "UTC", "type": "float"}
    }
  }
}
```

```
WindowProperty:ShadingControl,
INCIDENT SOLAR ON BLIND, !- Name
InteriorBlind, !- Shading Type
WIN-CON-SINGLEPANE WITH INTERIOR BLIND, !- Construction with Shading
OnIfScheduleAllows, !- Shading Control Type
WindowShadeSch, !- Schedule Name
, !- Setpoint {W/m2, W or deg C}
YES, !- Shading Control Is Scheduled
NO, !- Glare Control Is Active
, !- Shading Device Material Name
FixedSlatAngle, !- Type of Slat Angle Control for Blinds
; !- Slat Angle Schedule Name
```

```
Exterior:Lights,
ExtLights, !- Name
ExtLightSch, !- Schedule Name
5250, !- Design Level {W}
AstronomicalClock, !- Control Option
Grounds Lights; !- End-Use Subcategory
```

```
ExternalInterface,
PtolemyServer;
```

```
ExternalInterface:Schedule,
WindowShadeSch,
On/Off,
1.0;
```

```
ExternalInterface:Schedule,
ExtLightSch,
On/Off,
1.0;
```

```
Output:Variable,
```


```
*,
Site Outdoor Air Drybulb Temperature,timestep;
```

```
Output:Variable,
```

```
Zn001:Wall001:Win001,
Surface Outside Face Incident Solar Radiation Rate per Area,timestep;
```


```
Output:Variable,
```

```
*,
Site Diffuse Solar Radiation Rate per Area,timestep;
```




BSD Socket Communication with EnergyPlus™

- ▶ Agent creates socket server to exchange data with EnergyPlus™




Interaction EnergyPlus Simulation






Agent Synchronizes Inputs to EnergyPlus™

- ▶ Regardless of input method, agent waits until all **required** inputs are updated before sending message to EnergyPlus™





Multi-Agent Transactive Market Structure



Multi-Agent Transactive Market Demo with EnergyPlus™

The screenshot displays a software interface for a multi-agent transactive market demo. The main window is titled "Volttron [Running]" and contains several components:

- Code Editor:** Shows Python code for an agent's `handleCoolingSetPoint` method. The code includes logic to check for a 'topic' key in the output object and retrieve a device name.
- PyDev Package Explorer:** Lists project files and folders, including `.settings` and `config`.
- Figure 1 (Left):** A line graph showing "air quantity" (blue line) and "electricity quantity" (green line) over time. The air quantity spikes sharply at approximately 60 seconds, reaching a peak of about 80,000. The electricity quantity also spikes at the same time, reaching about 20,000. The x-axis ranges from 0 to 100, and the y-axis ranges from 0 to 80,000. A cursor is positioned at `x=69.763 y=6540.52`.
- Figure 1 (Right):** A line graph showing "CLGTEMPSETPOINT" for various zones (e.g., VAV-102, VAV-118, VAV-119, VAV-120, VAV-123A, VAV-123B, VAV-127A, VAV-127B, VAV-129, VAV-131, VAV-133, VAV-136, VAV-142, VAV-143, VAV-150, VAV-CORRIDOR, VAV-RESTROOM) over time. The y-axis ranges from 19.5 to 23.0. A horizontal red line is drawn at approximately 21.1. A cursor is positioned at `x=25.9817 y=22.646`.
- Log Console:** Displays a series of log messages from the agents, including "Sending" messages for various zones and equipment, such as "SEB/ZONE-VAV-127B Zone Mean Air Temperature 20.2383178866" and "SEB/AHU-001 Supply Equipment Outlet Node System Node Temperature 12.9979639333".