



Sandia
National
Laboratories



DOE Energy Storage Systems Research Program Annual Peer Review

September 24-26
San Francisco, CA

Design of the FESS 20 MW Frequency Regulation Plant

Imre Gyuk

Program Manager

Energy Storage Research

Department of Energy

Georgianne H. Peek

Project Manager

Electrical Energy Storage and Distributed

Energy Resources

Sandia National Laboratories

Rob Rounds

Sr. Engineer

Flywheel Installations

Beacon Power Corporation

Frequency Regulation


Benefit of Flywheel Based Frequency Regulation

Increases the Reliability and Stability of the Grid

- Frees up generator capacity
- Fast response may reduce quantity of necessary frequency regulation
- Increases market competition
- Benefit for deployment of wind power

Environmental


- No direct fossil fuel consumption
- Zero plant emissions



Beacon's Market Strategy

- Sell frequency regulation service
- Provide services via deregulated open-bid market
- Qualified with scale-power demonstration testing
- Commercialize with 25 kWh Gen 4 flywheel
- 1st service revenues in April 2008 (1 MW)
- 10 to 20 MW of service revenues by end of 2008

Beacon Power's
Gen4 Flywheel



Technology Comparison

- Emissions Analysis
- Cost to Provide Regulation Analysis

Development of 20 MW FR Plant Drawing Package

- Building designs and layouts
- Subsystem design
- Investigate LEED-NC rating

Technology Comparison

- Emissions Analysis – Presented on Monday Sept 24 by KEMA
- Cost performance analysis
 - Determine the cost to provide regulation for competing technologies
 - Flywheel
 - Battery
 - Natural gas fired baseline and peaker plants
 - Coal fired baseline and peaker plants
 - Cost areas include
 - Plant first cost
 - Maintenance cost
 - Fuel and electricity costs
 - Emissions cost

Technology Comparison

Assumptions (Continued)



Coal and Natural Gas 400 MW base loaded power plants

- Provide ± 20 MW regulation, or 5% of load
- Already participating in the market producing energy
- Constant cycling reduces efficiency

Coal and Natural Gas 75 MW peaker plants

- Provide ± 20 MW regulation
- Typically operational for six to eight hours a day
- Running lower efficiencies when below peak power

Flywheel and Battery 20 MW plants


- Provide ± 20 MW regulation
- Operational 24 hours a day
- Flywheel performance not affected by cycling

Technology Comparison - Emissions

CO₂ Reduction



From KEMA study: 20 MW of Regulation over 20-year operating life



Dramatic reduction in CO₂ emissions vs. present methods

KEMA cost performance analysis estimated the *cost for generators to provide* frequency regulation.

Cost Assumptions


- 30 Year life - Net Present Value with 7.5% discount rate
- Negative impact due to providing regulation
 - 12 to 17 trips per year expected
 - Reduced availability
 - Reduces plant life by approximately 1 year
 - 1 to 2 million Euros per year additional maintenance
- Battery data from EPRI-DoE Handbook
- Fossil fuel data from public domain and KEMA experience

Technology Comparison

Cost Comparison - Results



Cost model results per hour



Design of the 20 MW FESS Plant

Assumptions



Building

- Simple generic design
- Evaluate LEED-NC rating
- Evaluate PV to make up for system losses
- Minimize AC and heating load
- Operational 24 hours a day
- Minimize operational and capital costs




Process Cooling System

- Radiator based ECM cooling loop
- Chiller based flywheel cooling loop
- High level of system reliability

Electrical System

- One 20 MVA transformer
- Ten ~2 MVA transformers




FESS Regulation Building

Rendering




20 MW Plant containing 200 Flywheels

- Generic building design with a footprint of 22,400 ft²
 - 20,600 ft² Flywheel plant
 - 1,800 ft² Office/Conference/Storage Area ft²
- Simple construction allows for pre-engineered buildings
- Can be built without local water and sewer




FESS Regulation Building

Elevations




Flywheel Layout

Side View of Flywheels




Plant Layout

Top View



Site Layout

Stand alone site layout without city services



LEED-NC Certification

Leeds Comparison



LEED for New Construction v2.2 Registered Project Checklist

	Potential Points	Yes	?	No
Sustainable Sites	14 Points	8	1	5
Water Efficiency	5 Points	3	2	0
Energy & Atmosphere	17 Points	6	1	10
Materials & Resources	13 Points	6	3	4
Indoor Environmental Quality	15 Points	9	3	3
Innovation & Design Process	5 Points	1	0	4
Project Totals (pre-certification estimates)	69 Points	33	10	26

LEED-NC Ratings	
Platinum:	52-69 points
Gold:	39-51 points
Silver:	33-38 points
Certified:	26-32 points


LEED-NC Silver attainable with a potential to reach Gold

Design Criteria

- High temperature loop
- Low temperature loop
- Low maintenance
- Optimize performance

Two Design Approaches


- Centralized chiller room
 - More efficient design
- Modular Design
 - Higher redundancy for same cost
 - Allows for staged occupancy
 - Flexible design for 4 MW blocks



Electrical One Line Diagram

Transmission line Interconnection

- Single 20 MVA transformer
- Connect from 13.8 kV to 115 kV
- 10 2MVA transformers 480 V to 13.8 kV
- Fault tolerant design



Site Selection Criteria



Optimal site characteristics for new construction

- Close proximity to unconstrained transmission substation
- Inexpensive land
- Low electricity prices

Site Topography:	Minimal grade change throughout site.
Available Utilities:	Public Storm drain Public Sanitary connection Public Water connection Telephone
Zoning:	Industrial / Light Manufacturing –Typical. Allow for construction of facility without requiring rezoning, variances, etc. In some situations, actually only require administrative review by municipality
Parcel:	Vacant. No demolition / site preparation required.
Geotechnical:	Suitable bearing capacity without “over cutting”. Material could also allow for infiltration of storm water if acceptable my municipality.
Municipal Requirements:	Minor relative to landscaping, screenings, building materials, etc.

Evaluate the use of PV to recover plant energy losses

- Sized for maximum roof coverage
- Compared fixed vs. Single axis tracking
- Evaluated potential energy generation for two US sites
 - Southern California
 - Central MA

	Fixed Array	Single Axis
Southern California	1.8%	2.3%
Central Massachusetts	1.5%	1.8%

Results of design process


- Defined major areas that may be needed to be developed
 - Equipment required for substation
 - Land requirements if no city and septic and sewage are available
- Defined optimal process cooling specifications
- Completed plant one-line diagram
 - Needed for interconnection process
 - To determine cost/reliability
- Performed cost reduction of site/building design
- Performed cost reduction steps taken for building

“Plant style” design cost estimated to be \$10 to \$12 million

Initiated “substation style” design to reach \$5 million goal

Outdoor Substation Style Design

- Flywheels mounted in pre-cast housings
- Factory built MW module to provide
 - Plumbing
 - Electrical
 - Communications
- Minimal onsite construction
- Reduce timeline for build




Facility Development Goals

- Built at factory container Plumbing, electrical, communications
- Pre-cast foundations delivered to site ECM
- "Assembly" onsite

Process
Piping

Factory built
container

Pre-cast
concrete
form




Utilizes Designs Developed in Sandia Project

- Plant layout
- Process Piping
- Electrical Layout

Potential Savings

- Site costs
- Construction Time
- Required land



Sandia contract

- Final report on plant style design to be issued by: bla

Complete prefab derivative design

- Design work will continue after Sandia contract completion
- Complete engineering design
- Design factory built modules
- Hire contracting firm to provide site engineered drawings

First commercial plant (1 MW)

- Procure and assemble flywheels
- Procure support module
- Demonstrate system performance
- Install on site (April 2008)

Thanks



Thanks again to:

Imre Gyuk
Program Manager
Energy Storage Research
Department of Energy

Georgianne H. Peek
Project Manager
Electrical Energy Storage and
Distributed Energy Resources
Sandia National Laboratories

Garth Corey
Electrical Energy Storage and
Distributed Energy Resources
Sandia National Laboratories

Additional thanks to:

- Carter Burgess Consulting
- Richard C. Gross PE Inc.
- KEMA Consulting

Design Build – Process Piping

Cost Performance Analysis – Assumptions



Centralized vs. Modular Process Cooling

	Central Chiller Design	Modular Chiller Design
First Cost	Similar first cost on the chillers, higher piping cost if there is no common line to tie distribution chillers together.	Similar first cost on the chillers, higher construction cost due to bigger floor space required.
Maintenance	Shell and tube heat exchangers will require less cleaning cycles than the plate and frame heat exchangers associated with the Multi-stack options. Screw compressors require minimal maintenance.	More maintenance work required than the central plant due to more machines (chillers, pumps, etc) and the difference in heat exchangers.
Floor Area	Requires a central mechanical room	Requires more floor space in flywheel area. Chillers will be mingled with flywheels. Requires expansion of flywheel area.
Redundancy	2 chillers each at 60% total design load and each chiller has 2 screw compressors.	There will be 5 distribution chillers to meet 100% total design load and each serving one row of flywheels. One chiller will have two scroll compressors. Higher redundancy if chiller loops are tied together.
Efficiency	similar	
Water treatment requirements	Low.	The plate heat exchangers will require a higher level of demineralization to reduce scale on the plates than the shell and tube heat exchangers of the central plant option.