

Defense Nuclear Facilities Safety Board



FIRE PROTECTION TOPICS OF INTEREST



Overview of the Board



- Established by statute in 1989 to oversee the Department of Energy's operation of defense nuclear facilities.
- Jurisdiction covers current weapons-related facilities and facilities devoted to defense waste storage, processing and disposal.
- Agency's powers are quasi-regulatory. The Board can recommend changes, review and suggest standards, hold hearings, conduct investigations, and impose reporting requirements, but not issue penalties.

Fire Protection Activities



- Since its inception, the Defense Nuclear Facilities Safety Board (Board) has closely monitored the Department of Energy's (DOE) fire protection program.
- Two fire protection engineers supported by other technical staff and engineers manage this effort.
- What we look at:
 - Safety basis documentation content & assumptions
 - Quality of FHAs (content, completeness & assumptions)
 - Quality of engineering evaluations
 - Fire Protection Program

Fire Risk



- **“It is now established that at many nuclear facilities, fires are the dominant source of risk to workers and the public.”** (DNFSB/TECH-27, June 14, 2000)
- **Risk categories:**
 - New construction – New and challenging requirements
 - Aging legacy facilities – great challenge
 - ✦ May not have met codes in effect at time of construction
 - ✦ Fire risk not always understood and recognized
 - ✦ May not have been upgraded over time to keep pace with risk changes
 - Facilities undergoing decommissioning
 - ✦ Overall fire risk associated with D&D
 - ✦ Impairment of fire protection systems

Fire Risk



- **In past decades, several major fires have occurred at defense nuclear facilities.**
 - Rocky Flats
 - Paducah Gaseous Diffusion Plant
 - N-Reactor
- **Other lesser fires have also impacted environmental clean-up operations, in some cases halting operations for months.**
- **While no large fires have occurred in more recent times, this experience should not lead to complacency.**
- **A single major fire could result in serious damage to the DOE nuclear program and in the worst case, cause harm to workers or the public.**

Safety Related Fire Suppression



- **Projects are now implementing interim guidance (soon to be 1066 Appendix A).**
 - UPF at Y-12
 - PF-4 at LANL
 - CMRR at LANL
- **Bounding Fire .(Safety Basis)**
- **Design Basis Fire.**
 - NFPA guidance
 - Possibility of multiple common cause fires (seismic)
 - Consider conservative design margins

Safety Related Fire Suppression



- **Questions on the design basis fire:**
 - How many fires?
 - How large?
- **How to approach these questions?**
 - Deterministic – Criteria?
 - Probabilistic – PRA?
 - Something else?
- **No current accepted methodology.**
 - Must address uncertainty and conservative margins.
 - For some facilities combinations may be appropriate
- **Future discussions needed.**
 - Safety Basis and Fire Protection with other SMEs.

Fire Protection System Reclassification



- More older fire protection systems being reclassified from general service to safety class or safety significant.
- Key is the functional requirements from the DSA.
- Functional requirements drive design requirements.
- Just meeting minimum NFPA requirements may not be enough.
- Avoid “wand” waving.

Reclassification Continued:



- **Typical considerations for water based systems:**
 - Condition of pumps & tanks.
 - Pump meets demand & NFPA 25 compliant.
 - Tank meets supply and duration & NFPA 25 compliant—recent tank inspection.
 - Hydraulic analysis of water supply piping.
 - Hydraulic analysis of sprinkler system.
 - ✦ Must meet largest demand.
 - ✦ Multiple fires (where identified in safety basis).

Reclassification Issues Identified



- **Typical considerations for water based systems:**
 - Gap Analysis to current code requirements.
 - ✦ Resolution of deficiencies that may affect performance.
 - Interconnection of safety systems with system components classified as general service.
 - Design & installation did not meet code of record.
 - Changing conditions which negate code of record.
 - Failure to address issues identified during inspections or performance of Gap Analysis.
 - IT&M does not meet expectations for SS & SC.

Other Areas of Interest to Board



- **Fire Hazard Analysis & Engineering Evaluations:**
 - Quality, completeness.
 - Technically defensible.
 - Assumptions are appropriate and validated or protected.
- **Inspection, Testing & Maintenance:**
 - NFPA compliant.
 - Tracking & trending IT&M.
 - Special emphasis for safety class & safety significant systems.
 - Impairments and timely resolution.
- **SQA of Safety related design software.**
 - hydraulic calculations and others for safety related systems.
- **TSRs, LCOs and Compensatory Measurers.**

Defense Nuclear Facilities Safety Board



QUESTIONS?