

This document, concerning commercial and industrial pumps is an action issued by the Department of Energy. Though it is not intended or expected, should any discrepancy occur between the document posted here and the document published in the Federal Register, the Federal Register publication controls. This document is being made available through the Internet solely as a means to facilitate the public's access to this document.

6450-01-P

DEPARTMENT OF ENERGY

10 CFR Parts 429 and 431

[Docket No. EERE-2013-BT-TP-0055]

RIN 1905-AD50

Energy Conservation Program: Test Procedure for Pumps; Correction

AGENCY: Office of Energy Efficiency and Renewable Energy, Department of Energy.

ACTION: Notice of proposed rulemaking and public meeting; correction.

SUMMARY: On April 1, 2015, the U.S. Department of Energy (DOE) published in the Federal Register a notice of proposed rulemaking and public meeting for Energy Conservation Program: Test Procedure for Pumps. This document corrects terms in four equations.

DATES: [INSERT DATE OF PUBLICATION IN THE FEDERAL REGISTER].

FOR FURTHER INFORMATION CONTACT: Ashley Armstrong, U.S. Department of Energy, Office of Energy Efficiency and Renewable Energy, Building Technologies Office, EE-5B, 1000 Independence Avenue SW., Washington, DC 20585-0121. Telephone: (202) 586-6590. Email: ashley.armstrong@ee.doe.gov .

Corrections:

In the Federal Register published on April 1, 2015, in FR Doc. 2015-06945, make the following corrections:

1. On page 17604: Equation (6) is corrected by removing “13.46” and adding in its place “17.80”. The corrected equation reads as follows:

$$\eta_{pump,STD} = -0.85 * \ln(Q_{100\%})^2 - 0.38 * \ln(Ns) * \ln(Q_{100\%}) - 11.48 * \ln(Ns)^2 + 17.80 * \ln(Q_{100\%}) + 179.80 * \ln(Ns) - (C - 555.6)$$

Appendix A to Subpart Y of Part 431 - Uniform Test Method for the Measurement of Energy Consumption of Pumps. [Corrected]

2. On page 17645: The equation in section II.B.1.1.1 is corrected by removing “13.46” and adding in its place “17.80”. The corrected equation reads as follows:

$$\eta_{pump,STD} = -0.85 * \ln(Q_{100\%})^2 - 0.38 * \ln(Ns) * \ln(Q_{100\%}) - 11.48 * \ln(Ns)^2 + 17.80 * \ln(Q_{100\%}) + 179.80 * \ln(Ns) - (C - 555.6)$$

3. On page 17646: The equation in section III.D.1.2.1 is corrected by removing “MotorH” and adding in its place “MotorHP”. The corrected equation reads as follows:

$$L_{full,default} = \frac{MotorHP}{\left[\eta_{motor,full} / 100 \right]} - MotorHP$$

4. On page 17648: The equation in section V.D.1.2.1 is corrected by removing “MotorHPMotorH” and adding in its place “MotorHP”. The corrected equation reads as follows:

$$L_{full,default} = \frac{MotorHP}{\left[\eta_{motor,full} / 100 \right]} - MotorHP$$

Issued in Washington, DC, on April 20, 2015.



Kathleen B. Hogan
Deputy Assistant Secretary for Energy Efficiency
Energy Efficiency and Renewable Energy